# Practicus floor/roof drain DN 50, vertical, Slotted grating

Article information

Item no.: 45250.20
GTIN: 4026092092446
Price group: 10

Advantages

- Hygiene: hygienic, absolutely corrosion-free and durable material
- Sound insulation: outstanding sound insulation effect confirmed by the Fraunhofer Institute
- Fire protection: combinable with the Fire-Kit for fire and smoke protection

Description

The Practicus floor drain is used for point drainage and is equipped with a connection flange as well as a removable odour trap, a lip seal and a temporary protective cover. Including telescopic height-adjustable upper section made of ABS. The drain meets particular sound insulation requirements in accordance with the measurements of the Fraunhofer Institute in Stuttgart. The outlet socket is suitable for connection to SML cast iron pipes. With connection option for equipotential bonding.

Variant
System:	125
Waterproofing layer on the upper section:	Connection flange
Waterproofing layer on the drain body:	Connection flange
Sealing water height:	50 mm
Discharge rate (l/s) with 20 mm backwater:	2

General characteristics
Standard:	EN 1253-1
Nominal size (DN):	50
Outer diameter (OD):	50 mm
Inlet max. scoring (DN):	Z-19.53-2414,Z-19.17-1719

Dimensions

Subject to technical changes.

Vertical adjustment:	9 - 62 mm
Net weight:	0,57 kg
Gross weight:	0,89 kg
Cutout dimension, width:	180 mm
Cutout dimension, length:	180 mm
Vertical adjustment:	vertically adjustable upper section
Length:	156 mm
Width:	156 mm
Height:	210 mm
Packaging dimension:	length
Packaging dimension:	width
Packaging dimension:	height

Tank/drain body

Material of drain body:	PP
System:	vertical

Coverage features

Type of cover:	Slotted cover
Cover material:	Stainless steel 14301
Colour of cover:	silver
Width of cover:	120 mm
Length of cover:	120 mm
Cover locking:	unscrewed
Load class:	K 3 (EN 1253-1)
Grating colour:	Kessel
Rim length:	130 mm
Rim material:	130 mm
Upper section:	vertically adjustable
Upper section material:	ABS
Odour trap:	included

20.05.2024